LISTING SERVICE

LISTING No.	7120-0328:0145	Page 1 of 1
CATEGORY:	7120 -- ANNUNCIATORS	

LISTEE: Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: BillW@pottersignal.com

DESIGN: Model RA8F remote multiplex annunciator and RTI-1 Common trouble indicator. Refer to listee's data sheet for additional detailed product description and operational considerations .

INSTALLATION: In accordance with listee's printed installation instructions , applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as annunciator panel for use with listee's separately listed compatible Model FA -200 Series fire alarm control unit (CSFM Listing No. 7165-0328:155).

XLF: 7120-1477:0108

Date Issued: **July 01, 2012**   *Listing Expires*   **June 30, 2013**

Authorized By: *JASON DEWITT, Deputy State Fire Marshal*

Fire Engineering Division